

## SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

NO :HGP/23/SHLOK/50/3/2023-24

Date:- 10-08-2023

It is certified that an inspection team headed by Subramanya , Panchayat Development Officer from Rural development and panchayat Raj (RR&PR) , Huskur Grama Panchayat inspected the Shlok International School , Kaggalipura Village , Anekal Taluk , Sarjapura Hobli , Bangalore 560099 on 10-08-2023 and on the basis of water test report bearing number TC506923000011278F dated 05-08-2023 of Nexus Test Labs certified that the Shlok International School has safe drinking water facilities for the students and members of staff of the institution . School is also maintains the hygienic sanitation condition in the school Building and the campus as per norms prescribed by the Central/State/ UT. Govt.

This Certificate is valid till 10-08-2024.

Signature With Seal..... ಪಂಚಾಯತಿ ಅಧಿಕಾರಿ

Name :Subramanya

ಹುಸ್ಕುರು ಗ್ರಾಮ ಪಂಚಾಯತಿ  
ಸರ್ಕಾರಿ ಹೋಬ್ಬೆ, ಅನೇಕಲ್ ತಾ||

Designation : Panchayat Development officer

Name & Address of the Office Development :

Huskur Grama Panchayat ,Huskuru Village ,

Sarjapura Hobli , Anekal Taluk Bangalore .


To,

SHLOK INTERNATIONAL SCHOOL

Kaggalipura Village , Sarjapura Hobli

Anekal Taluk , Bangalore-560099

  
CHAIRMAN  
SHLOK INTERNATIONAL SCHOOL  
Kaggalipura Village, Sarjapura Hobli,  
Anekal Taluk, Bengaluru - 560 099.

  
ಪಂಚಾಯತಿ ಅಧಿಕಾರಿ  
ಹುಸ್ಕುರು ಗ್ರಾಮ ಪಂಚಾಯತಿ  
ಸರ್ಕಾರಿ ಹೋಬ್ಬೆ, ಅನೇಕಲ್ ತಾ||

  
PRINCIPAL  
SHLOK INTERNATIONAL SCHOOL  
Kaggalipura Village, Sarjapur Hobli,  
Anekal Taluk, Bangalore - 560 099

## TEST REPORT

Sample Code: TCS06923000011278F	Date of Sampling	05.08.2023
Name Of the Organization : M/s. SHLOK INTERNATIONAL SCHOOL Kaggalipura Village, Anekal Taluk, Sarjapura Hobli, Huskur Post, Bangalore.	Date of Receipt	05.08.2023
	Date of Analysis Started	05.08.2023
	Date of Analysis Completed	08.08.2023
	Date of Report	10.08.2023
	Environmental Condition	Ambient
Sample Particulars : Drinking Water	Sample Drawn By	Lab Representative
Source of Collection : R.O Plant	Report No	TCS06923000011278F
Sampling Method : IS 17614 (Part-1) : 2021 & IS 1622 :1981 - 2019	Condition of the Sample	Satisfactory

### RESULTS

S. No	Parameters	Protocol	Results	Standards IS : 10500 - 2012	
				Desirable Limits	Permissible Limits
1	pH Value	IS 3025 (Part - 11) 2017	6.56	6.5-8.5	No Relaxation
2	Colour, Hazen Unit	IS 3025 (Part - 4) 2017	2.0	5.0 Max	15
3	Odour	IS 3025 (Part - 6) 2017	Agreeable	Agreeable	Agreeable
4	Turbidity, NTU	IS 3025 (Part - 10) 2017	0.1	1.0 Max	5.0 Max
5	Total Dissolved Solids, mg/L	IS 3025 (Part - 16) 2017	45.6	500 Max	2000 Max
6	Total Hardness as CaCO <sub>3</sub> , mg/L	IS 3025 (Part - 21) 2019	7.9	200 Max	600 Max
7	Calcium as Ca, mg/L	IS 3025 (Part - 40) 2019	1.6	75 Max	200 Max
8	Magnesium as Mg, mg/L	IS 3025 (Part - 46) 2014	1.0	30 Max	100 Max
9	Alkalinity as CaCO <sub>3</sub> , mg/L	IS 3025 (Part - 23) 2019	20.0	200 Max	600 Max
10	Chlorides as Cl, mg/L	IS 3025 (Part - 32) 2019	14.4	250 Max	1000 Max
11	Sulphates as SO <sub>4</sub> , mg/L	IS 3025 (Part - 24) 2019	1.2	200 Max	400 Max
12	Nitrates as NO <sub>3</sub> , mg/L	IS 3025 (Part - 34) 2019	1.8	45 Max	No Relaxation
13	Iron as Fe, mg/L	IS 3025 (Part - 53) 2019	0.06	1.0 Max	No Relaxation
14	Fluoride as F, mg/L	IS 3025 (Part - 60) 2019	0.5	1.0 Max	1.5
<b>Microbiological Parameters</b>					
15	E.coli /100ml	IS 15185 - 2016 ( RA 2021)	Absent	Absent	Absent
16	Coliforms/100ml	IS 15185 - 2016 ( RA 2021)	Absent	Absent	Absent

INFERENCE: As per IS Standards 10500 - 2012, The above tested results are within the limits.

*H. S. Datta*  
ANALYZED BY

*P. S. Patil*  
MICROBIOLOGIST



*V. J. Simha Reddy*  
AUTHORISED SIGNATORIES

End of the Report

VJAYA SIMHA REDDY. P.R.  
Technical Manager

**Note:**

1. The results refer only to the tested samples and applicable Parameters
2. This report not to be reproduced wholly or in part & Cannot be used as an evidence in the Court of Law
3. Samples will be stored for a period of 15 Days on receipt. Gaseous samples, Food samples and Microbiology samples will be discarded after analysis
4. Nexus Test Labs doesnot hold any responsibility for variation in test results for samples kept on hold for want of clarification

*Shilpa*  
Sr. Microbiologist

**CHAIRMAN**  
NEXUS TEST LABS PVT. LTD.  
SHLOK INTERNATIONAL SCHOOL  
Kaggalipura Village, Sarjapura Hobli, Anekal Taluk, Bangalore - 560 099.

**PRINCIPAL**  
SHLOK INTERNATIONAL SCHOOL  
Kaggalipura Village, Sarjapura Hobli, Anekal Taluk, Bangalore - 560 099.  
Certificate No. : TC 5069



# ಹುಕ್ಕೂರು ಗ್ರಾಮ ಪಂಚಾಯತಿ ಕಾರ್ಯಾಲಯ

ಸರ್ಕಾರಿ ಪುರ ಹೋಬಳಿ, ಆನೇಕಲ್ ತಾಲ್ಲೂಕು ಬೆಂಗಳೂರು ನಗರ ಜಿಲ್ಲೆ

NO: HGP/23/Shlok/50/3/2023-24

Date: 08/05/2023

## SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

It is certified that an inspection team headed by Huskuru Grama Panchayathi / Subramanya, Panchayth Development Officer from Rural Development and Panchayath Raj (RD&PR) inspected the "SHLOK INTERNATIONAL SCHOOL", Kaggalipura Village, Sarjapura Hobli, Anekal Taluk, Bangalore on 08/05/2023 and found that "SHLOK INTERNATIONAL SCHOOL" has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building and the campus as per norms prescribed by the central /state/UT Gon

**The above is valid for a period of 1 (One) Year**

Signature with Seal:

Name: Subramanya

Designation: Panchayth Development Officer

Name & Adress of the Office/ Department:

Huskuru Grama Panchayathi, Huskuru Village,  
Sarjapura Hobli, Anekal Taluk Bangalore

To

SHLOK INTERNATIONAL SCHOOL  
Kaggalipura Village, Sarjapura Hobli  
Anekal Taluk, Bangalore-560099

CHAIRMAN

SHLOK INTERNATIONAL SCHOOL  
Kaggalipura Village, Sarjapura Hobli,

ಪಂಚಾಯತಿ ಅಧ್ಯಕ್ಷ ಅಧಿಕಾರಿ

ಹುಕ್ಕೂರು ಗ್ರಾಮ ಪಂಚಾಯತಿ

ಸರ್ಕಾರಿ ಪುರ ಹೋಬಳಿ, ಆನೇಕಲ್ ತಾ||

PRINCIPAL

SHLOK INTERNATIONAL SCHOOL  
Kaggalipura Village, Sarjapur Hobli,  
Anekal Taluk, Bangalore - 560099

J:\30-12-2022\2022-23\TP letters.docx